

PROTOCOL IMPLEMENTATION CONFORMANCE STATEMENT

BASIC INFORMATION

| | |
|---------------------------|---|
| Document Revision: | 1.05 |
| Issue Date: | 25 th March 2011 |
| Vendor Name: | Red Lion Controls |
| Product Name: | All Products Using Crimson 2.0 or Crimson 3.0 BACnet Slave Drivers |
| Product Model Numbers: | G3 Series of HMI. Data Station Plus Series and Modular Controller Series |
| Firmware Revision: | Crimson 2.0 Build 2.0.0.324 and Later and All Builds of Crimson 3.0 |
| BACnet Protocol Revision: | Version 1, Revision 5 |
| Product Description: | The products are advanced data-management devices that perform protocol conversion and data logging, and also provide a web-based virtual HMI facility. The G3 HMI products combine this functionality with color touchscreens for local viewing. The products support BACnet slave and master modes, over MS/TP, 802.3 and UDP/IP. |

BACNET STANDARDIZED DEVICE PROFILE (ANNEX L)

| | | |
|-------------------------------------|-------|--|
| <input checked="" type="checkbox"/> | B-ASC | BACnet Application Specific Controller |
| <input checked="" type="checkbox"/> | B-SS | BACnet Smart Sensor |
| <input checked="" type="checkbox"/> | B-SA | BACnet Smart Actuator |

BACNET INTEROPERABILITY BUILDING BLOCKS SUPPORTED (ANNEX K)

| | | |
|-------------------------------------|----------|--|
| <input checked="" type="checkbox"/> | DS-RP-B | Data Sharing, Read Property, B |
| <input checked="" type="checkbox"/> | DS-RPM-B | Data Sharing, Read Property Multiple, B |
| <input checked="" type="checkbox"/> | DS-WP-B | Data Sharing, Write Property, B |
| <input checked="" type="checkbox"/> | DM-DDB-B | Device Management, Dynamic Data Binding, B |
| <input checked="" type="checkbox"/> | DM-DOB-B | Device Management, Dynamic Object Binding, B |
| <input checked="" type="checkbox"/> | DM-DCC-B | Device Management, Device Communication Control, B |
| <input checked="" type="checkbox"/> | DM-RD-B | Device Management, Reinitialize Device, B |

STANDARD OBJECT TYPES

The following object types are supported...

- Analog Input, Analog Output, Analog Value
- Binary Input, Binary Output, Binary Value

- Device

The following conditions apply to all object types...

- Objects may be neither dynamically created nor deleted.
- No proprietary properties are implemented.
- No properties may be written unless required by the BACnet specification.
- No properties have range restrictions beyond those in the BACnet specification.

The only optional properties support are on the Device object and are as follows...

- Local_Time
- Local_Date

SEGMENTATION CAPABILITY

Segmentation is not supported.

DATA LINK LAYER OPTIONS

- BACnet IP (Annex J)
- ISO 8802-3 Ethernet (Clause 7)
- MS/TP Master (Clause 9) at 9600, 19200, 38400 and 78400 Baud.
- MS/TP Slave (Clause 9) at 9600, 19200, 38400 and 78400 Baud.

DEVICE ADDRESS BINDING

Static address binding is not supported.

NETWORKING OPTIONS

No networking options are supported.

CHARACTER SETS SUPPORTED

- ANSI X3.4

GATEWAY FUNCTIONALITY

The BACnet implementation is capable of exposing, and accepting writes to, any data items gathered from communications devices compatible with the Crimson runtime software. Data items may be exposed as any of the standard analog or binary object types. The list of available drivers is available from Red Lion's website.

REVISION HISTORY

Not Provided.