
Omron FINS over Ethernet Master Driver

Information Sheet for Crimson v2.0

Compatible Devices

Omron CJ or CS PLC fitted with appropriate Ethernet communications module.

Verified Device

Omron CJ1G CPU42H w/ ETN11

Accessible Data

Prefix	Description
CIO	CIO Area
W	Work Area
H	Holding Area
A	Auxiliary Area
TIM	Timer Area
CNT	Counter Area
DM	DM Area
EM	EM Area (Current)
DR	Data Register

Please note, Omron PLC should be in Monitor Mode for write operations.

Cable Information

Standard 10-Base-T Ethernet Cable