



Declaration of Conformity

This declaration of conformity is issued under the sole responsibility of the manufacturer.

Manufacturer's Name: Red Lion Controls
Manufacturer's Address: 3101 International Drive, Building 6, Mobile AL 36606 USA

USA: +1 (717) 767-6511

Netherlands: +31 (0) 33 4723-225

Germany: +49 (0) 89 5795 9421

China: +86 21.6113.3688

France: 33 (0) 1 84 88 75 25

UK: +44 (0) 20 3868 0909

Hereby, N-TRON Corporation declares that these industrial Ethernet devices are in compliance with the essential requirements and other relevant provisions of Directives 2014/30/EU, 2014/35/EU, 2011/65/EU (RoHS II) and (EC) 1907/2006 (REACH).

Listing of Conforming Devices

NTPS-24-1.3

DIN-Rail Power Supply for 1-phase Systems

Input: 100-240Vac, 0.6A, 50-60Hz

Output: 24-28Vdc, 1.3-1.1A, 30W

This product herewith complies with the requirements as presented below. Please reference "Power Supply Instruction Manual" as provided with each product for further regulatory specifications.



UL 508 Listed USA and Canada
File E328243



Class I, Div. 2, Groups A, B, C and D USA and Canada
File 255061
T-code T4



US Federal Communications Commission and (ISED) Canada
ANSI C63.4: American Standard for Methods of Measurement of Radio-Noise Emissions from low-voltage electrical and electronic Equipment in the range of 9kHz to 40 GHz.
US Code of Federal Regulations (CFR): Title 47, Part 15, Radio Frequency Devices, Subpart B, Unintentional Radiators.
Industry Canada ICES-003



European Union Conformité Européenne
EN 61000-6-1 and -2, 55024 Immunity Product Standard
EN 61000-3-2 Emissions Product Standard
EN 61000-3-3 Emissions Product Standard
EN 61000-4-1 EMC

EN 61000-6-3
EN 61000-6-4
EN 61204-3
EN 55011
EN 55022
EN 61000-4-2
EN 61000-4-3
EN 61000-4-4
EN 61000-4-5
EN 61000-4-6
EN 61000-4-8
EN 61000-4-11

Emissions Product Standard
Emissions Product Standard
Low Voltage Power Supplies; EMC Requirements
ISM
ITE
Electrostatic Discharge
Radio-frequency Electromagnetic Field AM
Electrical Fast Transients
Surge
Radio-frequency Common Mode
Power-frequency Magnetic Field
Voltage Dips and Interruptions

Underwriters Laboratories, LLC.
333 Pfingsten Road
Northbrook, IL 60062-2096 USA
File E328243

CSA Group
178 Rexdale Blvd.
Toronto, ON
Canada M9W 1R3
File 255061



Mr. John Maynard - Regulatory Manager