



Tel +1 (717) 767-6511  
Fax +1 (717) 764-0839  
www.redlion.net

# FlowCom Master Driver

## Information Sheet for Crimson v2.0

---

### Compatible Devices

FLOWCOM INSTRUMENTS

### Verified Device

FLOWCOM S8

### Accessing Data

Crimson allows entry of Instruction Codes 20H – FFH. Definition of each Instruction Code is dependant upon the FlowCom Instrument device configuration and/or programming. Please note string arrays are not fully compatible with this driver.

### Read Operations

All string tags associated with read operations should be set to a length of 80 characters. If using string arrays to divide a string in to sub strings, the arrays read policy should be set to "Read Whole Array".

### Write Operations

All write only operations should be assigned to a tag designated as such. It is always good practice to clear a string before writing a similar string.

### Cable Information

G3 RS232 Port	FlowCom Connector
Pin 2 – RX	B
Pin 3 –COMM	A
Pin 5 - TX	D